

# VISUAL INSPECTION SUMMARY REPORT

## Optronics S.A de C.V.

## FiberChek2™

March 21, 2014, 12:09:21 PM

© 2008 Westover Scientific, Inc.

LINEA 4 , Jumper FC/UPC-FC/UPC Monomodo 9/125 Simplex de 10m riser de2mm

<http://www.westoverfiber.com>

<b>Inspection Result / Fiber Name:</b>		<b>**FAIL**</b>
File Name:	<b>S5052333-08140021B</b>	
Serial Number:		
Lot Number:		
IL:		
RL:		
Profile:	SM, Post Polish (IEC-61300-3-35 Table 3)	

<b>Inspection Summary:</b>							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ <sup>2</sup> )	Result	Count
Zone A	0	25	PASS	0	0	FAIL	1
Zone B	25	120	PASS	0	0	PASS	1
Zone C	120	130	PASS	0	0	PASS	1
Zone D	130	250	PASS	2	3.5876	PASS	0
Zone E	250	1000	PASS	3	4.03605	PASS	0
Epoxy Gap:	PASS		Fiber Type:	Simplex		Core Size:	9

