

VISUAL INSPECTION SUMMARY REPORT

Optronics S.A de C.V.

FiberChek2™

March 24, 2014, 5:49:35 PM

© 2008 Westover Scientific, Inc.

LINEA 4 , Jumper LC/UPC-FC/UPC Monomodo 9/125 Simplex de 3m riser de2mm

<http://www.westoverfiber.com>

Inspection Result / Fiber Name:		**PASS**
File Name:	S5052333-08140008A	
Serial Number:		
Lot Number:		
IL:		
RL:		
Profile:	SM, Post Polish (IEC-61300-3-35 Table 3)	

Inspection Summary:							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ ²)	Result	Count
Zone A	0	25	PASS	0	0	PASS	0
Zone B	25	120	PASS	0	0	PASS	0
Zone C	120	130	PASS	0	0	PASS	0
Zone D	130	250	PASS	2	1.56957	PASS	0
Zone E	250	1000	PASS	2	3.5876	PASS	0
Epoxy Gap:	PASS		Fiber Type:	Simplex		Core Size:	9

