

# VISUAL INSPECTION SUMMARY REPORT

## Optronics,S.A de C.V.

## FiberChek2™

March 25, 2014, 7:22:30 AM

© 2008 Westover Scientific, Inc.

EQ V Linea 2 , Jumper LC-LC Multimodo 50/125 Duplex de 3m Riser de 2mm

<http://www.westoverfiber.com>

<b>Inspection Result / Fiber Name:</b>		<b>**FAIL**</b>
File Name:	M5052333-08140022B1	
Serial Number:	M5052333-08140022	
Lot Number:		
IL:	<0.20 dB	
RL:	>40.00 dB	
Profile:	MM, Post Polish (IEC-61300-3-35 Table 6) OM2	

<b>Inspection Summary:</b>							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ²)	Result	Count
Zone A	0	65	FAIL	1	951.189	PASS	0
Zone B	65	120	FAIL	2	951.731	PASS	0
Zone C	120	130	PASS	0	0	PASS	0
Zone D	130	250	PASS	2	2.40914	PASS	0
Zone E	250	1000	PASS	2	0.722742	PASS	0
Epoxy Gap:	PASS		Fiber Type:	Simplex		Core Size:	50

