

VISUAL INSPECTION SUMMARY REPORT

Optronics,S.A de C.V.

FiberChek2™

March 25, 2014, 1:41:38 AM

© 2008 Westover Scientific, Inc.

EQ V Linea 2 , Jumper LC-LC Multimodo 62.5/125 Duplex de 3m Riser de 2mm

<http://www.westoverfiber.com>

Inspection Result / Fiber Name:		**FAIL**
File Name:	M5052333-08140008A2	
Serial Number:	M5052333-08140008	
Lot Number:		
IL:	<0.20 dB	
RL:	>40.00 dB	
Profile:	MM, Post Polish (IEC-61300-3-35 Table 6) OM1	

Inspection Summary:							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ²)	Result	Count
Zone A	0	65	PASS	0	0	PASS	0
Zone B	65	120	PASS	1	0.0547392	PASS	1
Zone C	120	130	PASS	0	0	PASS	1
Zone D	130	250	FAIL	4	100.063	PASS	0
Zone E	250	1000	PASS	5	1.75165	PASS	0
Epoxy Gap:	PASS		Fiber Type:	Simplex		Core Size:	62.5

