

VISUAL INSPECTION SUMMARY REPORT

Optronics,S.A de C.V.

FiberChek2™

March 25, 2014, 12:31:33 AM
EQ R Linea 2 , Jumper LC-LC Multimodo 62.5/125 Duplex de 3m Riser de 2mm

© 2008 Westover Scientific, Inc.
<http://www.westoverfiber.com>

| | | |
|--|--|-----------------|
| Inspection Result / Fiber Name: | | **PASS** |
| File Name: | M5052333-08140012B2 | |
| Serial Number: | M5052333-08140012 | |
| Lot Number: | | |
| IL: | <0.20 dB | |
| RL: | >40.00 dB | |
| Profile: | MM, Post Polish (IEC-61300-3-35 Table 6) OM1 | |

| Inspection Summary: | | | | | | | |
|----------------------------|--------------|-------|-------------|---------|-----------|------------|-------|
| Zone Name | Diameter (μ) | | Defects | | | Scratches | |
| | Inner | Outer | Result | Count | Area (μ²) | Result | Count |
| Zone A | 0 | 65 | PASS | 0 | 0 | PASS | 0 |
| Zone B | 65 | 120 | PASS | 0 | 0 | PASS | 1 |
| Zone C | 120 | 130 | PASS | 0 | 0 | PASS | 1 |
| Zone D | 130 | 250 | PASS | 4 | 7.22742 | PASS | 0 |
| Zone E | 250 | 1000 | PASS | 3 | 223.568 | PASS | 0 |
| Epoxy Gap: | PASS | | Fiber Type: | Simplex | | Core Size: | 62.5 |

