

# VISUAL INSPECTION SUMMARY REPORT

## Optronics S.A. de C.V.

## FiberChek2™

March 14, 2014, 12:21:42 AM

© 2008 Westover Scientific, Inc.

EQ G Linea 3 , Jumper LC/UPC-LC/UPC Monomodo 9/125 Duplex de 2m Riser de 2mm

<http://www.westoverfiber.com>

<b>Inspection Result / Fiber Name:</b>		<b>**PASS**</b>
File Name:	S5052333-11140007B2	
Serial Number:	S5052333-11140007	
Lot Number:		
IL:		
RL:		
Profile:	SM, Post Polish (IEC-61300-3-35 Table 3)	

<b>Inspection Summary:</b>							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ²)	Result	Count
Zone A	0	25	PASS	0	0	PASS	0
Zone B	25	120	PASS	0	0	PASS	0
Zone C	120	130	PASS	1	0.237814	PASS	0
Zone D	130	250	PASS	0	0	PASS	0
Zone E	250	1000	PASS	0	0	PASS	0
<b>Epoxy Gap:</b>	PASS		<b>Fiber Type:</b>	Simplex		<b>Core Size:</b>	9

