

VISUAL INSPECTION SUMMARY REPORT

Optronics S.A. de C.V.

FiberChek2™

March 14, 2014, 2:57:55 AM

© 2008 Westover Scientific, Inc.

EQ G Linea 3 , Jumper LC/UPC-LC/UPC Monomodo 9/125 Duplex de 2m Riser de 2mm

<http://www.westoverfiber.com>

Inspection Result / Fiber Name:		**FAIL**
File Name:	S5052333-11140014A2	
Serial Number:	S5052333-11140014	
Lot Number:		
IL:		
RL:		
Profile:	SM, Post Polish (IEC-61300-3-35 Table 3)	

Inspection Summary:							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ²)	Result	Count
Zone A	0	25	PASS	0	0	PASS	0
Zone B	25	120	PASS	3	2.91322	PASS	1
Zone C	120	130	PASS	0	0	PASS	1
Zone D	130	250	PASS	0	0	PASS	0
Zone E	250	1000	PASS	5	2.37814	PASS	0
Epoxy Gap:	PASS		Fiber Type:	Simplex		Core Size:	9

