

VISUAL INSPECTION SUMMARY REPORT

Optronics,S.A de C.V.

FiberChek2™

March 25, 2014, 5:29:32 AM

© 2008 Westover Scientific, Inc.

EQ R Linea 2 , Jumper LC/UPC-LC/UPC Monomodo 9/125 Duplex de 3m Riser de 2mm

<http://www.westoverfiber.com>

Inspection Result / Fiber Name:		**FAIL**
File Name:	S5052333-08140017B1	
Serial Number:	S5052333-08140017	
Lot Number:		
IL:	<0.20 dB	
RL:	>55.00 dB	
Profile:	SM, Post Polish (IEC-61300-3-35 Table 3)	

Inspection Summary:							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ²)	Result	Count
Zone A	0	25	PASS	0	0	PASS	0
Zone B	25	120	FAIL	3	211.523	PASS	0
Zone C	120	130	PASS	5	222.183	PASS	0
Zone D	130	250	PASS	0	0	PASS	0
Zone E	250	1000	PASS	2	1.20457	PASS	0
Epoxy Gap:	PASS		Fiber Type:	Simplex		Core Size:	9

