

# VISUAL INSPECTION SUMMARY REPORT

## Optronics,S.A de C.V.

## FiberChek2™

March 25, 2014, 5:32:35 AM

© 2008 Westover Scientific, Inc.

EQ R Linea 2 , Jumper LC/UPC-LC/UPC Monomodo 9/125 Duplex de 3m Riser de 2mm

<http://www.westoverfiber.com>

<b>Inspection Result / Fiber Name:</b>		<b>**FAIL**</b>
File Name:	S5052333-08140018B2	
Serial Number:	S5052333-08140018	
Lot Number:		
IL:	<0.20 dB	
RL:	>55.00 dB	
Profile:	SM, Post Polish (IEC-61300-3-35 Table 3)	

<b>Inspection Summary:</b>							
Zone Name	Diameter (μ)		Defects			Scratches	
	Inner	Outer	Result	Count	Area (μ <sup>2</sup> )	Result	Count
Zone A	0	25	PASS	0	0	PASS	0
Zone B	25	120	PASS	0	0	PASS	0
Zone C	120	130	PASS	0	0	PASS	0
Zone D	130	250	PASS	0	0	PASS	0
Zone E	250	1000	FAIL	2	56.6148	PASS	0
Epoxy Gap:	PASS		Fiber Type:	Simplex		Core Size:	9

